



California Geological Survey - Note 48

Checklist for the Review of Engineering Geology and Seismology Reports for
California Public Schools, Hospitals, and Essential Services Buildings

January 1, 2011

Note 48 is used by the California Geological Survey (CGS) to review the geology, seismology, and geologic hazards evaluated in reports that are prepared under California Code of Regulations (CCR), Title 24, California Building Code. CCR Title 24 applies to California Public Schools, Hospitals, Skilled Nursing Facilities, and Essential Services Buildings. The Building Official for public schools is the Division of the State Architect (DSA). Hospitals and Skilled Nursing Facilities in California are under the jurisdiction of the Office of Statewide Health Planning & Development (OSHPD). The California Geological Survey serves under contract with these two state agencies.

Project Name: _____ Location: _____
 OSHPD or DSA File #: _____ Reviewed By: _____
 Date Reviewed: _____ California Certified Engineering Geologist #: _____

Checklist Item or Topic Within Consulting Report	Adequately Described; Satisfactory	Additional Data Needed; Not Satisfactory
NA = not applicable NR = not addressed by consultant and therefore not reviewed at this time		

Project Location

1. Site Location Map, Street Address, County Name: Correctly plot site on a 7½-minute USGS quadrangle base-map.		
2. Plot Plan with Exploration Data and Building Footprint: One boring or exploration shaft per 5000 ft ² , with minimum of two for any one building. Exploratory trench locations.		
3. Site Coordinates (Latitude & Longitude):		

Engineering Geology/Site Characterization

4. Regional Geology and Regional Fault Maps: Concise page-sized illustrations with site plotted.		
5. Geologic Map of Site: Detailed (large-scale) geologic map with proper symbols and geologic legend.		
6. Subsurface Geology: Engineering geologic description summarized from boreholes or trench logs. Summarize ground water conditions.		
7. Geologic Cross Sections: Two or more detailed geologic sections with pertinent foundations and site grading.		
8. Active Faulting & Coseismic Deformation Across Site: Show proposed structures in relation to Alquist-Priolo Earthquake Fault Zones and/or any potential fault rupture hazard identified from the Safety Element of the local agency (city or county); show location of fault investigation trenches; 50-foot setbacks perpendicular from fault plane and proposed building footprints.		
9. Geologic Hazard Zones (Liquefaction & Landslides): <i>(If applicable)</i> Show proposed structures in relation to CGS official map showing zones of required investigation for liquefaction and landslide, and/or any pertinent geologic hazard map from the Safety Element of the local agency (city or county).		
10. Geotechnical Testing of Representative Samples: Broad suite of appropriate geotechnical tests.		
11. Consideration of Geology in Geotechnical Engineering Recommendations: Discuss engineering geologic aspects of excavation/grading/fill activities, foundation and support of structures. Include geologic and geotechnical inspections and problems anticipated during grading. Special design and construction provisions for bearing capacity failure and/or footings or foundations founded on weak or expansive soils. Consideration of seismic compression of fills; cut/fill differential settlement.		

Seismology & Calculation of Earthquake Ground Motion

12. Evaluation of Historical Seismicity: Prepare a short description of how historical earthquakes have affected the site.		
13. Classify the Geologic Subgrade (Site Class): 2010 CBC Table 1613A.5.2 and §1613A.5.5.		
14. General Procedure Ground Motion Analysis: Follows 2010 CBC §1613A.5. Report parameters S _s , S ₁ , S _{DS} and S _{D1} . Recommended method for establishing map values found at: http://earthquake.usgs.gov/research/hazmaps/design/ .		
15. Seismic Design Category: Report if S ₁ > 0.75		

Checklist Item or Topic Within Consulting Report	Adequately Described; Satisfactory	Additional Data Needed; Not Satisfactory
NA = not applicable NR = not addressed by consultant and therefore not reviewed at this time		
16. Site-Specific Ground Motion Analysis: <i>(If applicable)</i> Required for sites where conditions described in 2010 CBC §1615A.1.2 apply. Provide probabilistic MCE, deterministic MCE and deterministic lower limit. See requirements in CBC §1803A.6.2. Provide design response spectrum that meets ASCE 7 §21.3. Also provide S_{DS} and S_{D1} values that meet ASCE 7 §21.4.		
17. Deaggregated Seismic Source Parameters: <i>(If applicable)</i> Provide controlling magnitude (M_w) and distance to fault, if needed for liquefaction, slope stability analysis or for earthquake record selection.		
18. Time Histories of Earthquake Ground Motion: <i>(If applicable)</i> Compute target spectra, justify selected earthquake records, scale to target to meet ASCE 7 §16.1.3 or §17.3 and show initial and scaled time histories and response spectra.		

Liquefaction/Seismic Settlement Analysis

19. Geologic Setting for Occurrence of Liquefaction: Perform screening analysis to identify where the following conditions apply: <ul style="list-style-type: none"> ◆ depth of highest historical ground water surface <50 ft. ◆ low-density, non-plastic alluvium, typically $SPT (N_1)_{60} < 30$. 		
20. Seismic Settlement Calculations: <i>(If applicable)</i> Evaluate both saturated and unsaturated layers of the entire soil column; based on several detailed geologic cross sections. Provide calculations (no estimates) including all input parameters. Evaluate liquefaction using highest historical ground water elevation. Evaluate using peak ground acceleration based on site-specific study or peak ground acceleration equal to $S_{DS}/2.5$.		
21. Other Liquefaction Effects <i>(If applicable)</i> Bearing capacity failure and/or lateral spread		
22. Mitigation Options for Liquefaction: <i>(If applicable)</i> Discuss effectiveness of options to mitigate liquefaction effects. Acceptance criteria for ground-improvement schemes.		

Slope Stability Analysis

23. Geologic Setting for Occurrence of Landslides: Characterize the potential for landsliding both on and off-site affecting proposed project.		
24. Determination of Static And Dynamic Strength Parameters: <i>(If applicable)</i> Conduct appropriate laboratory tests to determine material strength for both static and dynamic conditions.		
25. Determination of Pseudo-Static Coefficient (K_{eq}): <i>(If applicable)</i> Recommended procedure available from http://www.conservation.ca.gov/cgs/shzp/webdocs/Documents/sp117.pdf		
26. Identify Critical Slip Surfaces for Static and Dynamic Analyses: <i>(If applicable)</i> Failure surfaces should be modeled to include existing slip surfaces, discontinuities, geologic structure and stratigraphy; include appropriate ground water conditions.		
27. Dynamic Site Conditions: <i>(If applicable)</i> Site response analysis and topographic effects should be considered, if appropriate.		
28. Mitigation Options for Landsliding/Other Slope Failure: <i>(If applicable)</i> Discuss effectiveness of options to mitigate landsliding/slope failure effects. Acceptance criteria for ground-improvement schemes.		

Other Geologic Hazards or Adverse Site Conditions

These exceptional geologic hazards do not occur statewide; however, they may be pertinent to a particular site. Where these conditions exist relevant information should be communicated to the design team.

29. Expansive Soils		
30. Corrosive/Reactive Geochemistry of Geologic Subgrade: soluble sulfates and corrosive soils.		
31. Conditional Geologic Assessment: Including but not limited to - A. Hazardous materials methane gas, hydrogen-sulfide gas, tar seeps; B. Volcanic eruption ; C. Flooding Riverine (FEMA FIRM's for 100-year flood)/Alluvial fan/Dam inundation, is the site elevated or protected from the hazard; D. Tsunami and seiche inundation ; E. Radon-222 gas ; F. Naturally occurring asbestos in geologic formations associated with serpentinite; refer to CGS SP 124; G. Hydrocollapse of alluvial fan soils due to anthropic use of water; H. Regional subsidence ; I. Clays and cyclic softening .		

Report Documentation

32. Geology, Seismology, and Geotechnical References		
33. Certified Engineering Geologist: (2010 CBC §1803A.1)		
34. Registered Geotechnical Engineer: (2010 CBC §1803A.1)		